



At the Heart of Community

Sewer/Water Service Line Repair



BEFORE Completing the Application

- *Contact Public Works and Building & Zoning at 847-540-1696 to obtain information specifically related to water/sewer repair for that site.
- *Call J.U.L.I.E. (800-892-0123) a minimum of 72 hours before digging.

What to Submit

- *Completed application.

*The submittal for the water service repair permit is required to indicate the minimum separation between the sewer and water service lines, materials for repair and that all work related to the repair of the Village water main and the repair of the water service line be performed by an Illinois Licensed Plumbing Contractor.

*Sewer service line repairs within 15'-0" of the home/building require a licensed plumber to perform the repairs.

Inspections

- *Inspections are scheduled for A.M. or P.M. Monday through Friday with 24 hours advance notice at 847-540-1696.
- *On-site inspection by Illinois licensed plumbing inspector to observe capping off of water and sewer lines prior to backfill.
- *Final inspection.

Costs

\$173.00 Permit Fee
37.00 Plan Review Admin Fee \$37.00

PLUS

*Water/Sewer connection fees as calculated by Public Works Utilities Division per ordinance.

*Sewer connection fees as calculated by Lake County.

*Street/Parkway opening deposit.

*If final inspection is not approved prior to expiration date on permit, the deposit is forfeited to the Village.

Note:

*Sewer service lines which shear-off within 24" of foundation wall shall be replaced through the wall.

*All through wall sewer water or gas piping shall be sleeved as Illinois plumbing code 890. 180c) and d) requires. *See all additionally required items on attached illustration.*

*Sleeves shall be solidly grouted/cemented into wall.

*Sewer shall not be cemented into sleeve.

*Annular space around sewer within sleeve shall be filled with oakum tightly packed and secured in place with either 2" compacted lead wool, cold tar, link seal or fernco coupling if sleeve extends min. 2" into building.

I have read and reviewed these requirements.

Signature of Applicant

Date