



At the Heart of Community

Electrical

Service Upgrade & Panel Replacement

Rules & Restrictions

- *All installations shall comply with the 2011 National Electric Code and the 2012 International Building Codes.
- *Proper grounding is required for the installation of all new electric services, panel replacement, all electric wiring and/or repairs. This may mean making changes to your existing grounding and bonding systems.
- *Two 8' burial depth copper ground rods are required on the exterior of the house with the proper sized ground wire going to your metal socket. Ground wires are sized to the wire used in the service entrance. A ground wire is also required on the inside of your house between the main disconnect panel and the water service on the street side of the water meter. In conjunction with this ground wire there should also be a bonding jumper across the water meter.
- *Call J.U.L.I.E. (800-892-0123) before digging.

What to Submit

- *Completed application.
- *Provide list of circuit breakers in main and sub-panels and load of existing circuits.
- *Provide additional information and drawings showing locations, clearances, unusual installations, etc.

Service Size (amp)	<input type="checkbox"/> 100	<input type="checkbox"/> 200	<input type="checkbox"/> 400	<input type="checkbox"/> _____
Service Entrance	<input type="checkbox"/> Overhead	<input type="checkbox"/> Underground		
Service Entrance Conduit Size	_____in	<input type="checkbox"/> IMC	<input type="checkbox"/> RMC	<input type="checkbox"/> HWA
Service Entrance Wire Size	_____ga	<input type="checkbox"/> Copper Only		
Main Disconnect Located	<input type="checkbox"/> In main panel	<input type="checkbox"/> At meter socket		
Distance from Disconnect to Main Panel	_____ft (over 5' RMC required)			
Service Ground Wire	<input type="checkbox"/> 100 A - (#8 minimum)	<input type="checkbox"/> 200 A - (#4 minimum)		
Water Service Jumper & Ground Wire	<input type="checkbox"/> 400 A - (1/0 minimum)			

Costs

- Plan Review Fee
- Permit Fee (fee determined at plan review)
- \$105.00 Building Deposit -refunded in accordance with Municipal Code Title 8, Chapters 2-6, Sections A-E. Allow 4-6 weeks for refund after final inspection has taken place.
- *If final inspection is not scheduled and approved prior to expiration date on permit, the building deposit will be forfeited to the Village.

Note:

*If an inspector needs to return more than once for the same phase of any required inspection, a \$85.00 residential re-inspection fee or a \$170.00 commercial re-inspection fee will be required to be paid before the re-inspection takes place.

Inspections

*Inspections are scheduled for A.M. or P.M. Monday through Friday with 24 hours advance notice. Call before 3:00 P.M. the day before you want your inspection. Same day re-inspections are not available.

*Rough inspection

*Final inspection

I have read and reviewed these requirements. _____
 Signature of Applicant Date